

CP-1500 and SP-1500 Calibration Chart

Height (in.)	Volume (Gal)							
		50	1,468.40		38.75	1,138.01	27.5	807.62
		49.75	1,461.06		38.5	1,130.67	27.25	800.28
61	1,791.45	49.5	1,453.71		38.25	1,123.32	27	792.94
60.75	1,784.10	49.25	1,446.37		38	1,115.98	26.75	785.59
60.5	1,776.76	49	1,439.03		37.75	1,108.64	26.5	778.25
60.25	1,769.42	48.75	1,431.69		37.5	1,101.30	26.25	770.91
60	1,762.08	48.5	1,424.35		37.25	1,093.96	26	763.57
59.75	1,754.74	48.25	1,417.00		37	1,086.61	25.75	756.23
59.5	1,747.39	48	1,409.66		36.75	1,079.27	25.5	748.88
59.25	1,740.05	47.75	1,402.32		36.5	1,071.93	25.25	741.54
59	1,732.71	47.5	1,394.98		36.25	1,064.59	25	734.20
58.75	1,725.37	47.25	1,387.64		36	1,057.25	24.75	726.86
58.5	1,718.03	47	1,380.29		35.75	1,049.90	24.5	719.52
58.25	1,710.68	46.75	1,372.95		35.5	1,042.56	24.25	712.17
58	1,703.34	46.5	1,365.61		35.25	1,035.22	24	704.83
57.75	1,696.00	46.25	1,358.27		35	1,027.88	23.75	697.49
57.5	1,688.66	46	1,350.93		34.75	1,020.54	23.5	690.15
57.25	1,681.32	45.75	1,343.58		34.5	1,013.19	23.25	682.81
57	1,673.97	45.5	1,336.24		34.25	1,005.85	23	675.46
56.75	1,666.63	45.25	1,328.90		34	998.51	22.75	668.12
56.5	1,659.29	45	1,321.56		33.75	991.17	22.5	660.78
56.25	1,651.95	44.75	1,314.22		33.5	983.83	22.25	653.44
56	1,644.61	44.5	1,306.87		33.25	976.48	22	646.10
55.75	1,637.26	44.25	1,299.53		33	969.14	21.75	638.75
55.5	1,629.92	44	1,292.19		32.75	961.80	21.5	631.41
55.25	1,622.58	43.75	1,284.85		32.5	954.46	21.25	624.07
55	1,615.24	43.5	1,277.51		32.25	947.12	21	616.73
54.75	1,607.90	43.25	1,270.16		32	939.77	20.75	609.39
54.5	1,600.55	43	1,262.82		31.75	932.43	20.5	602.04
54.25	1,593.21	42.75	1,255.48		31.5	925.09	20.25	594.70
54	1,585.87	42.5	1,248.14		31.25	917.75	20	587.36
53.75	1,578.53	42.25	1,240.80		31	910.41	19.75	580.02
53.5	1,571.19	42	1,233.45		30.75	903.06	19.5	572.68
53.25	1,563.84	41.75	1,226.11		30.5	895.72	19.25	565.33
53	1,556.50	41.5	1,218.77		30.25	888.38	19	557.99
52.75	1,549.16	41.25	1,211.43		30	881.04	18.75	550.65
52.5	1,541.82	41	1,204.09		29.75	873.70	18.5	543.31
52.25	1,534.48	40.75	1,196.74		29.5	866.35	18.25	535.97
52	1,527.13	40.5	1,189.40		29.25	859.01	18	528.62
51.75	1,519.79	40.25	1,182.06		29	851.67	17.75	521.28
51.5	1,512.45	40	1,174.72		28.75	844.33	17.5	513.94
51.25	1,505.11	39.75	1,167.38		28.5	836.99	17.25	506.60
51	1,497.77	39.5	1,160.03		28.25	829.65	17	499.26
50.75	1,490.42	39.25	1,152.69		28	822.30	16.75	491.91
50.5	1,483.08	39	1,145.35		27.75	814.96	16.5	484.57
50.25	1,475.74							

CP-1500 and SP-1500 Calibration Chart

16.25	477.23	5	146.84
16	469.89	4.75	139.50
15.75	462.55	4.5	132.16
15.5	455.20	4.25	124.81
15.25	447.86	4	117.47
15	440.52	3.75	110.13
14.75	433.18	3.5	102.79
14.5	425.84	3.25	95.45
14.25	418.49	3	88.10
14	411.15	2.75	80.76
13.75	403.81	2.5	73.42
13.5	396.47	2.25	66.08
13.25	389.13	2	58.74
13	381.78	1.75	51.39
12.75	374.44	1.5	44.05
12.5	367.10	1.25	36.71
12.25	359.76	1	29.37
12	352.42	0.75	22.03
11.75	345.07	0.5	14.68
11.5	337.73	0.25	7.34
11.25	330.39	0	0.00
11	323.05		
10.75	315.71		
10.5	308.36		
10.25	301.02		
10	293.68		
9.75	286.34		
9.5	279.00		
9.25	271.65		
9	264.31		
8.75	256.97		
8.5	249.63		
8.25	242.29		
8	234.94		
7.75	227.60		
7.5	220.26		
7.25	212.92		
7	205.58		
6.75	198.23		
6.5	190.89		
6.25	183.55		
6	176.21		
5.75	168.87		
5.5	161.52		
5.25	154.18		